


Classification	UA-Series English FAQ-Dev-006						
Author	Eva Li	Version	1.0.0	Date	2023,7	Page	1 / 3

● **How to check the latest data records after the data is collected by UA Server and stored in MySQL Server? (Take MySQL Workbench 8.0.32 as an example)**

The UA series products of ICP DAS provide a service for transferring Modbus TCP/RTU data into the database. This FAQ explains how to check the latest data in the database.

(In this example, we use UA-5231M + DL-302 with Modbus TCP protocol + Win10, 64 bits operating system + MySQL Server 8.0.32 + MySQL Workbench 8.0.32)



**1. Create MySQL environment and set up UA Server**


Please refer to FAQ-Dev-002.

The link is as follows:

<https://www.icpdas.com/web/product/download/iiot/ua/faq/UA-en-FAQ-Dev-002.pdf>

**2. How to use MySQL Workbench to check the latest data after the data has been stored in the database?**

1. Execute the MySQL Workbench program to log in



Classification	UA-Series English FAQ-Dev-006						
Author	Eva Li	Version	1.0.0	Date	2023,7	Page	2 / 3

2. After logging in to the database, check whether the UA series data has been successfully in the table.

(1) Click "schemas" on the bottom left

(2) Click "Create a new SQL tab for executing queries" on the upper left

(3) Click Refresh

(4) Check the data table

(5) write command

(6) Click the lightning button above to execute

Date	Time	Name	Value	Status
2023-06-28	14:28:59	MTCP_No.1_DL-302_AI.Temperature_Fahrenheit	7802	GOOD
2023-06-28	14:28:59	MTCP_No.1_DL-302_AI.Dew_point_temperature_Fahrenheit	6305	GOOD
2023-06-28	14:28:59	MTCP_No.1_DL-302_AI.Temperature_Celsius	2557	GOOD
2023-06-28	14:28:59	MTCP_No.1_DL-302_AI.CO2	494	GOOD
2023-06-28	14:28:59	MTCP_No.1_DL-302_AI.Dew_point_temperature_Celsius	1725	GOOD
2023-06-28	14:28:59	MTCP_No.1_DL-302_AI.Relative_humidity	6013	GOOD
2023-06-28	14:28:54	MTCP_No.1_DL-302_AI.Dew_point_temperature_Celsius	1725	GOOD
2023-06-28	14:28:54	MTCP_No.1_DL-302_AI.CO2	493	GOOD
2023-06-28	14:28:54	MTCP_No.1_DL-302_AI.Temperature_Celsius	2556	GOOD
2023-06-28	14:28:54	MTCP_No.1_DL-302_AI.Temperature_Fahrenheit	7800	GOOD
2023-06-28	14:28:54	MTCP_No.1_DL-302_AI.Relative_humidity	6013	GOOD
2023-06-28	14:28:54	MTCP_No.1_DL-302_AI.Dew_point_temperature_Fahrenheit	6305	GOOD
2023-06-28	14:28:49	MTCP_No.1_DL-302_AI.Dew_point_temperature_Celsius	1727	GOOD
2023-06-28	14:28:49	MTCP_No.1_DL-302_AI.Relative_humidity	6013	GOOD
2023-06-28	14:28:49	MTCP_No.1_DL-302_AI.Dew_point_temperature_Fahrenheit	6308	GOOD
2023-06-28	14:28:49	MTCP_No.1_DL-302_AI.CO2	493	GOOD
2023-06-28	14:28:49	MTCP_No.1_DL-302_AI.Temperature_Fahrenheit	7804	GOOD
2023-06-28	14:28:49	MTCP_No.1_DL-302_AI.Temperature_Celsius	2558	GOOD

- (1) Click "schemas" on the bottom left
- (2) Click "Create a new SQL tab for executing queries" on the upper left
- (3) Click Refresh
- (4) Check the data table
- (5) Write command
- (6) Click the lightning button above to execute

**Example description:** This example is to query the first 100 records.

Command example:

**SELECT \* FROM Factory\_UA\_5231.DL\_302 order by date desc, time desc limit 100;**

Classification	UA-Series English FAQ-Dev-006						
Author	Eva Li	Version	1.0.0	Date	2023,7	Page	3 / 3

SELECT \* FROM Factory\_UA\_5231.DL\_302 order by date desc, time desc limit 100;



Search the Database [Factory\_UA\_5231]  
and its Table [DL\_302].



Show the lasted 100 records by the order  
of [date] and [time].