Classification	System and Ap	plication F	AQ on WinCE	PAC		No.	4-004-00
Author	Vic-Tsai	Version	1.0.0	Date	2018/04/27	Page	1/2

How to clear the device name listed on Eshell

Platform OS Version PAC Utility Version WinPAC All Versions All Versions			
WinPAC All Versions All Versions ViewPAC All Versions All Versions	OS Version	Platform OS Version PAC Ut	lity Version
ViewPAC All Versions All Versions	All Versions	WinPAC All Versions All V	ersions
	All Versions	ViewPAC All Versions All V	ersions

Every time when Eshell searches a device, the device name will be added to a list without clearing. Therefore the list will be longer and longer (See "Diagram-1") and become difficult to recognize which one is the right choice.

Select Device			
Enter Device Name:		OK	
VP_2540		Cancel	
Or <u>S</u> elect From the List			
VP_1149 VP_1958	<u> </u>	Reset devices to automatically put	
VP_2540		names on the	
WINPAC270_59544	\sim	list.	
Diag	gram-1		

The following is the solution:

Step 1: Copy "Eshell" folder to PC.

(There will be two files in it. One is ESHELL.EXE and another is registry_clear.exe Download path:

CD:\napdos\w<mark>p-8x4x_ce50\PC_Tools\Eshe</mark>ll

http://ftp.icpdas.com/pub/cd/winpac/napdos/wp-8x4x_ce50/pc_tools/Eshell)

Step 2: Execute registry_clear.exe and click "Clear" button

• • • •	
🖳 Eshell registry clearer	
Clear	
	ICP DAS Co., Ltd. Technical document

Classification	System and Ap	plication F	AQ on WinCE	PAC		No.	4-004-00
Author	Vic-Tsai	Version	1.0.0	Date	2018/04/27	Page	2/2

Step 3: After clearing device name, the Eshell windows shows to search device.

Select Device	X
Enter Device Name:	ОК
	Cancel
Or <u>S</u> elect From the List	
	Reset devices to automatically put names on the list.



ICP DAS Co., Ltd. Technical document