

Classification	ISaGRAF English FAQ-006						
Author	Chun Tsai	Version	1.0.0	Date	Aug. 2007	Page	1 / 1

Can I use ISaGRAF PAC (I-8417/8817/8437/8837, I-7188EG/XG) as a Modbus Master PAC to gather data from other Modbus devices?

Ans: Yes. These ISaGRAF PACs all support Modbus Slave & Master protocol. PC, HMI & touch monitor which support Modbus can talk to these PACs by connecting to their Modbus slave ports. At the same time, these PACs can also use up to two of their Modbus master ports to talk to other devices which support Modbus slave protocol.

	I-8417/8817	I-8437/8837	I-7188EG	I-7188XG
COM1	(RS232) 1. Modbus slave 2. Modbus master			(RS232 or RS485) Modbus slave
COM2	(RS485) Modbus slave	N/A	(RS485) 1. Modbus master protocol 2. I-7000 & I-87K remote I/O protocol User-defined or 3 rd party protocol	
Ethernet	N/A	1. Modbus slave (TCP/IP) 2. Ebus	1. Modbus slave (TCP/IP) 2. Ebus	N/A
COM3	1. Modbus master (RS232 or RS485) 2. Fbus (RS485) 3. I-7000 & I-87K remote I/O protocol (RS485) 4. User-defined or 3 rd party protocol (RS232 or RS485)		(Need extra X503 to X514) User-defined or 3 rd party protocol (RS232 or RS485)	
COM4	(RS232) 1. Modbus master 2. I-7000 & I-87K remote I/O protocol 3. User-defined or 3 rd party protocol 4. Modem-Link			
COM5 to COM8	(Need extra I-8112/8114 or I-8142/8144) User-defined or 3 rd party protocol			
COM9 to COM20	(RS232 or RS485)		N/A	

Note: Sometimes Modbus slave protocol for serial port is also named as “Modbus RTU” or “Modbus serial”.

Click the link for more ISaGRAF FAQ:

<http://www.icpdas.com/en/faq/index.php?kind=280#751>